


2008 Annual Water Quality Drinking Report

SANITARY DISTRICT NO. 4 — TOWN OF BROOKFIELD



Administrative Office:

Now located at the
TOWN HALL

645 North Janacek Road
Brookfield, Wisconsin
Phone: 262.798.8631
Fax: 262.796.0339

Monday - Friday
8 a.m. to 4:30 p.m.

Mailing Address:

P.O. Box 1296
Brookfield, WI 53008-1296

Superintendent's Office:

150 South Barker Road
Brookfield, WI
Phone: 262.798.8629
Fax: 262.798.8633

Water System Information

We are pleased to present this year's Annual Water Quality Report. This report is designed to inform you about the quality of water and the service we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water comes from the shallow dolomite aquifer. We have six wells and they all flow through filters to remove the iron that is predominating in the shallow aquifer. Because of the water quality, we are only required to add a little chlorine for disinfection and the water is ready for the distribution system. The Sanitary District's licensed operators are here to ensure the excellent water quality 24 hours a day, every day of the year. On an average day, the Sanitary District provides the Town of Brookfield with 1 million gallons of water.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Sanitary District No. 4 is pleased that the drinking water provided to you is **safe** and **meets all** federal and state requirements. If you have any questions about this report, or concerning your water utility, please contact our superintendent, Terry Heidmann, at 262-798-8629. We want you, our valued customers, to be informed about their water utility. We encourage you to attend the Sanitary District meetings, which are generally held on the first and third Tuesdays of each month, beginning at 7:00 p.m. at the Town Hall, 645 North Janacek Road. Information, which includes our billing rates, is also available on the Town of Brookfield's website at <http://www.townofbrookfield.com/SD4.html>.

UTILITIES SUPERINTENDENT

Terry R. Heidmann
262.798.8629 (Direct Line)

*Available for phone calls from
8:00 a.m. to 3:00 p.m.*

Sources of Water

Source id	Source	Depth (in feet)
1	Groundwater	350
2	Groundwater	314
3	Groundwater	450

Source id	Source	Depth (in feet)
4	Groundwater	370
5	Groundwater	220
6	Groundwater	202

A summary of the source water assessment for TOWN OF BROOKFIELD SAN DIST #4 is available at:
http://prodmtext00.dnr.state.wi.us/pls/inter1/pk_swap_web.p_swap_summary?i_ro_seq_no=139218

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Number of Contaminants Required to be Tested

This table displays the number of contaminants that were required to be tested in the last five years. The CCR may contain up to five years worth of water quality results. If a water system tests annually, or more frequently, the results from the most recent year are shown on the CCR. If testing is done less frequently, the results shown on the CCR are from the past five years.

Contaminant Group	No. of Contaminants
Disinfection Byproducts	1
Inorganic Contaminants	16
Microbiological Contaminants	1
Radioactive Contaminants	2
Synthetic Organic Contaminants including Pesticides and Herbicides	23
Unregulated Contaminants	4
Volatile Organic Contaminants	21

Disinfection Byproducts

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2008)	Violation	Typical Source of Contaminant
HAA5 (ppb)	60	60	6	3 - 6	07/09/2007	NO	

Inorganic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2008)	Violation	Typical Source of Contaminant
ANTIMONY TOTAL (ppb)	6	6	.1 (average)	nd-.2		NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
ARSENIC (ppb)	10	n/a	1 (average)	1 - 2		NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)	2	2	.173 (average)	.150 - .200		NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM (ppm)	100	100	3 (average)	3 - 4		NO	Discharge from steel and pulp mills; Erosion of natural deposits
COPPER (ppm)	AL=1.3	1.3	.247 (average)	.0510 - .6530		NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
FLUORIDE (ppm)	4	4	.2 (average)	.2 - .3		NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
LEAD (ppb)	AL=15	0	1.6 (average)	nd - 6.90		NO	Corrosion of household plumbing systems; Erosion of natural deposits
NICKEL (ppb)	100		3.9333 (average)	3.5000 - 4.5000		NO	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.
SELENIUM (ppb)	50	50	1 (average)	nd - 2		NO	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)	n/a	n/a	68.00 (average)	51.00-87.00		NO	n/a

Radioactive Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2008)	Violation	Typical Source of Contaminant
RADIUM, (226 + 228)	5	0	2.1 (average)	1.8 - 2.5		NO	Erosion of natural deposits

Unregulated Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2008)	Violation	Typical Source of Contaminant
BROMODICHLOROMETHANE (ppb)	n/a	n/a	1.79 (average)	.28 - 3.20		NO	n/a
BROMOFORM (ppb)	n/a	n/a	2.00 (average)	1.10-2.90		NO	n/a
CHLOROFORM (ppb)	n/a	n/a	1.20 (average)	1.10 - 1.30		NO	n/a
DIBROMOCHLOROMETHANE (ppb)	n/a	n/a	3.85 (average)	2.30 - 5.4		NO	n/a
DIBROMOMETHANE (ppb)	n/a	n/a	.25	.25		NO	n/a
SULFATE (ppm)	n/a	n/a	54.33 (average)	51.00 - 58.00		NO	n/a

Volatile Organic Contaminants

Contaminant (units)	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2008)	Violation	Typical Source of Contaminant
P-DICHLOROBENZEN (ppb)	75	75	.2	.2		NO	Discharge from industrial chemical factories
TTHM (ppb)	80	0	19.8	10.7 - 19.8	07/09/2007	NO	By-product of drinking water chlorination

Definition of Terms

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.